

Certificate of Compliance

Certificate Number **20110106 - R26331**
Report Reference **R26331, 2010 August 18**
Issue Date **2011 January 06**

Page 1 of 2



Issued to: **GMP TECHNICAL SOLUTIONS PVT LTD**

MANTHALA, GUNAI RD, VIA BAROTIWALA
DISTRICT SOLAN, KASAUL
BADDI HP 174103 INDIA

*This is to certify that
representative samples of*

SWINGING-TYPE FIRE DOORS


Please Refer Addendum page for product details.

*Have been investigated by Underwriters Laboratories Inc.® in
accordance with the Standard(s) indicated on this Certificate.*

Standard(s) for Safety: The Basic standard used to investigate products in this category is ANSI/UL 10C, "Positive Pressure Fire Tests of Door Assemblies."

Additional Information: See UL On-Line certification Directory at www.UL.com for additional information.

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

William R. Carney,
Director of the North American Certification Program.

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark Services are provided on behalf of Underwriters Laboratories Inc (UL) or any authorized licensee of UL.
For questions in India, you may call 91-80-4138 4400, UL India pvt. Ltd

Certificate of Compliance

Certificate Number **20110106 - R26331**
Report Reference **R26331, 2010 August 18**
Issue Date **2011 January 06**

Page 2 of 2



This is to verify that representative samples of the products as specified on this certificate were tested
According to the current UL requirements

Max Rating	Opening Type	Hollow Metal Type Door	Steel Covered Composite Type Door
1-1/2 Hr	Single or Pair with Astragal	X	—
	Single Point Lock/Flush Bolts		
	Fire Exit Hardware		

William R. Carney,
Director of the North American Certification Program.

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark Services are provided on behalf of Underwriters Laboratories Inc (UL) or any authorized licensee of UL.
For questions in India, you may call 91-80-4138 4400, UL India pvt. Ltd